



FAISALABAD ELECTRIC SUPPLY CO. LTD.

☎ 041-9220397
 ☎ 041-9220691
 ✉ cedevfesco@yahoo.com

Office of the,
 Chief Engineer (Development),
 PMU FESCO Faisalabad

EVALUATION REPORT

(As per Rule 35 of Public Procurement Rules, 2004)

1. Name of Procuring Agency Faisalabad Electric Supply Company (FESCO)
2. Method of Procurement Single Stage Single Envelope
3. Title of Procurement Transformer oil Class-1 in new Steel Drum of capacity "205" Liter as per IEC-60296, IEC-60244, DDF should be less than 0.0005%, resistivity at 900 C must be granter than 1000GΩ Origin of base oil KSA/UAE/China or equivalent
4. Tender Inquiry No. NCB-683/FESCO/PMU/GSO/2024-25
5. Date & Time of Bidding Closing 11:00 A.M. 09.01.2025
6. Date & Time of Bidding Opening 12:00 Noon. 09.01.2025
7. No. of Bids Received 04 No.
8. Criteria for Bid Evaluation As per Bidding Document
9. Details of Bids (s) Evaluation As under:

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (If applicable)	Financial (If applicable)		
Pak Trans Oil (Pvt) Ltd	---	---	21.977	i) The bid declared Commercially Responsive . ii) The bid declared Technically Non-Responsive due to: The schedule of Technical Data submitted with the bid. But the bidder did not attach oil performance test report to conform the oil sample as per required specification.
Bukhat Trading (Pvt) Ltd	---	---	15.484	i) The bid declared Commercially Non-Responsive due to: ➤ The bidder submitted bid with contractual deviations details below: (a) The non-availability of Feed Stock Base Oil is beyond the control of Manufacturer and supplier. Non-availability or delay in availability of raw material during the currency of contract shall be considered and allowed as Force Majeure. (b) Extension of Time shall be applicable in force majeure and extension in time in current situation of Any reason of non-availability of transporter due to social/political/biological/Nature-act/ weather/government/authorities/ Transporter Association.

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004		
	Technical (If applicable)	Financial (If applicable)		S#	Technical Parameters Required	Technical Parameters Offered
Bukhat Trading (Pvt) Ltd	---	---	15.484		ii) The bid declared Technically-Non-Responsive due to: The schedule of Technical Data and test report submitted with the bid are not conforming to tender specifications, detail below:	
				1	Dielectric Dissipation Factor should be less than 0.0005%	Less than 0.005
Associated Commercial Agencies	---	---	22.563	The bid declared Commercially and Technically Responsive .		
M. Abubakar Traders	---	---	49.770	i) The bid declared Commercially Responsive . ii) The bid declared Technically Non-Responsive due to: <ul style="list-style-type: none"> > The bidder did not submit manufacturing experience of more than five (05) years. > The bidder did not submit schedule of technical data (detail parameters of transformer oil, origin/make etc) with the bid. > The bidder did not attach oil performance test report to conform the oil sample as per required specification. 		

Lowest Evaluated Bidder: M/s ASSOCIATED COMMERCIAL is Commercially and Technically Most Advantageous Evaluated Responsive Bidder

11. Any other additional/supporting information, the procuring agency may like to share.

Endst. No. 1046 /CE(Dev)PMU FESCO

Dated: 28-3-25

Forwarded to Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.


Chief Engineer (Development)
PMU, FESCO Faisalabad

CC:-

> Master File.