

LOAD SHEDDING PLAN FESCO

(2018-19)

CATEGORY-I	Number of feeders	Interruptions	00:30 to 01:30	01:30 to 02:30	02:30 to 03:30	03:30 to 04:30	04:30 to 05:30	05:30 to 06:30	06:30 to 07:30	07:30 to 08:30	08:30 to 09:30	09:30 to 10:30	10:30 to 11:30	11:30 to 12:30	12:30 to 13:30	13:30 to 14:30	14:30 to 15:30	15:30 to 16:30	16:30 to 17:30	17:30 to 18:30	18:30 to 19:30	19:30 to 20:30	20:30 to 21:30	21:30 to 22:30	22:30 to 23:30	23:30 to 24:30	Total MW	Avg MW	
			Urban (1ST Circle)	67	4								134		149				165		181								
Semi Urban (1ST Circle)	15	4								38		43		46					48									175	7
Urban (2ND Circle)	56	4									164		174			188		200										725	30
Semi Urban (2ND Circle)	11	4											31	33					33							28	124	5	
Urban (Jhang Circle)	21	4			52				51		55													61			220	9	
Semi Urban (Jhang Circle)	29	4		77					78		84													89			327	14	
Urban (Sargodha Circle)	51	4										153			169							169			174		666	28	
Semi Urban (Sargodha Circle)	22	4				66							77			83		82									308	13	
Rural (1ST Circle)	30	5							79			86		87						88				91			430	18	
Rural (2ND Circle)	29	5						69						80			87		78							70	384	16	
Rural (Jhang Circle)	97	5						238				251		262					258		236						1245	52	
Rural (Sargodha Circle)	79	5								141					174			175		153			170				812	34	
Commercial Dominated (FESCO)	14	4							22		28									49				36			134	6	
Tubewell Dominated(1ST Circle)	30	5									100		102					106			101					93	502	21	
Tubewell Dominated(2ND Circle)	22	5							50				57			57				53					40		257	11	
Tubewell Dominated(Jhang Circle)	24	5	83				83				98		100													88	453	19	
Tubewell Dominated(Sargodha Circle)	29	5									72			73	76					65				67			354	15	
Industrial Dominated (1ST Circle)	66	3												234	229							207					670	28	
Industrial Dominated (2ND Circle)	68	3														254	255						226				735	31	
Industrial Dominated (Jhang Circle)	10	3													41	42								38			122	5	
Industrial Dominated (Sargodha Circle)	13	3												36	35							22					93	4	
Independent (OTHERS)	21	4			8								12	12							9						42	2	
CATEGORY-II	11	6		22					24				22				28		23						23		142	6	
Independent Textile (1ST Circle)	86	0																									0	0	
Independent Textile (2ND Circle)	6	0																									0	0	
Independent Textile (Jhang Circle)	12	0																									0	0	
Independent Textile (Sargodha Circle)	7	0																									0	0	
Independent Non Textile (FESCO)	44	0																									0	0	
Continuous Process (40% Load Reduction)	5	0																									0	0	
Cements Factories (40% Load Reduction)	3	0																									0	0	
Exempted Feeders of Hospitals, WASA & Defence(FESCO)	42																												
A=TOTAL LOAD SHED (MW)	1020		83	99	60	66	83	306	303	312	600	683	575	693	609	705	626	577	620	444	411	398	434	384	378	97	9550	398	
B=FESCO COMPUTED DEMAND (MW)			2371	2317	2239	2239	2206	2256	2294	2286	2471	2567	2664	2665	2673	2696	2746	2757	2694	2534	2378	2490	2486	2452	2449	2466	59396	2475	
FESCO SHARE REQUIRED (MW)			2287	2218	2179	2173	2123	1950	1991	1973	1871	1884	2089	1972	2064	1991	2120	2180	2074	2090	1967	2092	2052	2068	2070	2368	49846	2077	