

## ENSALATAN THE TRUE SUPPLY GOR LITTER

8 041-9220397

≈ 041-9220691

Office of the, Chief Engineer (Development), PMU FESCO Faisalabad

S cedevfesco@yahoo.com

## EVALUATION REPORT (As per Rule 35 of Public Procurement Rules, 2004)

Name of Procuring Agency

Faisalabad Electric Supply Company (FESCO)

2 Method of Procurement

Single Stage Single Envelope

3 Title of Procurement

132 KV Capacitor Bank (48-MVAR) with Rack, Explosion fuse & Bus Bar and Posts complete set (Each Capacitor Unit 400KVAR) & Neutral C.T as per concerned WAPDA/

PEPCO/NTDC Specification (amended to date)

4 Tender Inquiry No.

NCB-614/FESCO/PMU/GSC/2024-25

5 PPRA Ref. No. (TSE)

TS543217E dated 19.07.2024

6 Date & Time of Bidding Closing

12:50 A.M. 12.08.2024

7 Date & Time of Bidding Opening

11:00 P.M. 12.08.2024

8 No. of Bids Received

02 Nos.

9 Criteria for Bid Evaluation

As per Bidding Document

10 Details of Bids (s) Evaluation

As under:

N	Marks		Evaluated	Rule/Regulation/SBD/Policy/Basis for
Name of Bidder	Technical (If applicable)	Financial (If applicable)	Cost (Million Rs.)	Rejection/Acceptance as per Rule 35 of PP Rules, 2004
Siddique Sons Engineering (Pvt) Ltd			209.800	The bid declared Commercially & Technically Responsive
M.N. Enterprises  Litar (CC&B) Letar (MIS) Letar (AMI) Lety Director (ERP) Lety Director (NWA) Lety Director (CC&		3/8/24	169.600	<ul> <li>i) The bid declared Commercially Non-Responsive due to:- The bidder did not submit copies of 132KV Capacitor bank and neutral CT. The bidder is not in line with contractual experience criteria provided in Clause-4 of Section-III of bidding document, "The bidder must have atleast two (02) No. of contracts successfully completed within the last five (05) years".</li> <li>ii) The bid declared Technically Non-Responsive due to:-</li> <li>Not in line with Manufacturing and Technical Experience criteria provided in Clause-5 of Section-III of bidding document, "The manufacturer qualifies manufacturing experience of more than five (5) years and also qualifies for satisfactory operation more than three (03) years".</li> <li>The schedule of technical data of Neutral CT is not submitted with the bid.</li> </ul>

Lowest Evaluated Bidder:

M/s Siddique Sons Engineering (Pvt) Ltd, Lahore.

01.5%

11.	Any other additional/supporting information, the page	rocuring agency may like to share.
-----	---	------------------------------------

Endst. No. 8728-29 /CE(Dev)PMU FESCO

Dated: \_\_\_

19-9-24

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor, FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

Chief Engineer (Development)
PMU, FESCO, Faisalabad

CC:-

. Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.

2. Master File.