



041-9220397
 041-9220691
 cedevfesco@yahoo.com

Office of the,
 Chief Engineer (Development),
 PMU FESCO Faisalabad

EVALUATION REPORT
 (As per Rule 35 of Public Procurement Rules, 2004)

1. Name of Procuring Agency: Faisalabad Electric Supply Company (FESCO)
2. Method of Procurement: Single Stage Single Envelope
3. Title of Procurement:
 - i) 66KV Pin Insulator
 - ii) 11 KV Post Insulator
 - iii) 132KV Post Insulator with SSS, Terminal Connector & G-Bolt
 - iv) LV Bushing for 20/26 MVA Power Transformers
4. Tender Inquiry No.: NCB-643/FESCO/PMU/GSC&GSO/2024-25
5. PPRA Ref. No. (TSE): TS543222E dated 10.07.2024
6. Date & Time of Bidding Closing: 12:00 A.M. 13.08.2024
7. Date & Time of Bidding Opening: 11:00 Noon 13.08.2024
8. No. of Bids Received: 01 No.
9. Criteria for Bid Evaluation: As per Bidding Document
10. Details of Bids (s) Evaluation: As under:

2007
 Daily No. 23/9/24
 FESCO Faisalabad

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules; 2004
	Technical (If applicable)	Financial (If applicable)		
EMCO Industries Ltd	---	---	05.949	i) The bid declared Commercially Non-Responsive due to:- <ul style="list-style-type: none"> Not in line with contractual experience criteria provided in Clause-4 of Section-III of bidding document, "The bidder must have atleast two (02) No. of contracts successfully completed within the last five (05) years", the bidder did not attach two contracts successfully completed within the last five years for 66KV pin insulator and LV Bushing for 20/26 MVA Power Transformer. ii) The bid declared Technically Non-Responsive due to:- <ul style="list-style-type: none"> The manufacturer does not qualify manufacturing experience of more than five (5) years and satisfactory operation more than three (03) years for Serial No. 01 and 04. The bidder offered and submitted technical data of 33KV Line Post Insulator as an alternate of 66KV Pin Insulator. But no such provision is defined / allowed in bidding document. Drawings of LT Bushing attached with bid does not indicate creepage distance of offered material.

Handwritten signatures and dates: 23/9/24, 23/9, Rohina

Section
 PMU Section
 Engineer / Care Taker

- | | | | | |
|--|--|--|--|---|
| | | | | <ul style="list-style-type: none">The bidder did not submit type test report for 66KV pin insulator, 11KV Post Insulator & LV Bushing for 20/26 MVA Power Transformer and an unconditional undertaking that in case of award of contract, if submitted type test reports are not according to NTDC type test policy, he will carry out fresh type tests under witness of NTDC/DISCO's Inspectors as per NTDC revised type test policy within the quoted Bid price and without affecting the delivery / completion period as mentioned. in the Bidding Documents. <u>The bidder has not complied with Clause 7.3 (Type Tests Report), Section-III, Evaluation and Qualification Criteria of Bidding Documents.</u> |
|--|--|--|--|---|

st Evaluated Bidder:

The participated bidder is declared Non-Responsive.

- Any other additional/supporting information, the procuring agency may like to share.

ndst. No. 8730-31 /CE(Dev)PMU FESCO

Dated: 19-9-24

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor, BC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.

Chief Engineer (Development)
PMU, FESCO, Faisalabad

CC:-

- Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.
- Master File.