



FAISALABAD ELECTRIC SUPPLY CO. LTD.

041-9220397
041-9220691
cedevfesco@yahoo.com

Office of the,
Chief Engineer (Development),
PMU FESCO Faisalabad

EVALUATION REPORT

(As per Rule 35 of Public Procurement Rules, 2004)

- Name of Procuring Agency: Faisalabad Electric Supply Company (FESCO)
- Method of Procurement: Single Stage Single Envelope
- Title of Procurement: Supply of mobile 2-stage High vacuum, Transformer Oil Filtration & Dehydration Plant make Japan/UK/Europe/USA or equivalent
- Tender Inquiry No. *9289* Dairy No. *24/5/2024* NCB-597/FESCO/PMU/GSC&GSO/2023-24
- PPRA Ref. No. (TSE) *FESCO* TS534669E dated 12.03.2024
- Date & Time of Bidding Closing: 11:00 A.M. 26.03.2024
- Date & Time of Bidding Opening: 12:30 P.M. 26.03.2024
- No. of Bids Received: 05 No.
- Criteria for Bid Evaluation: As per Bidding Document
- Details of Bids (s) Evaluation: As under:

26/03/24

Director (CC&B)
Director (MIS)
Director (AMT)
Deputy Director (ERP)
Deputy Director (NWA)
Deputy Director (CC&B)
Deputy Director (DBA)
Assistant Director (P.S.A)
Assistant Director (MIS)
Admn Section
Accounts Section
Sub Engineer / Care Taker
PA to DG (IT)

Name of Bidder	Marks		Evaluated Cost (Million Rs.)	Rule/Regulation/SBD/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (If applicable)	Financial (If applicable)		
SADIDIANS	---	---	48.889	The bid declared Technically Non-Responsive due to: i) The schedule of technical data submitted with the bid is not conforming to tender specifications detailed below: a) Working Vacuum: -0.06 ~ -0.095 Mpa b) Working Pressure: ≤ 0.4 Mpa ii) The broucher / catalogue containing technical parameters is not signed & stamped.
M.N Enterprises	---	---	50.000	The bid declared Technically Non-Responsive due to: i) The schedule of technical data submitted with the bid is not conforming to tender specifications detailed below: a) Working Discharge Pressure: ≤ 0.4 Mpa ii) The broucher / catalogue containing technical parameters is not signed & stamped.
KAC Engineering Pakistan	---	---	73.700	The bid declared Commercially Non-Responsive due to: i) Form Fin-2 attached by the bidder indicates average annual turnover in last 3-years more than 02 times of the quoted price whereas audit reports attached indicates sales of 205,758,980 , 76,144,200 & 46,857,500 for the year 2023,2022 & 2021 respectively. The average

				annual turnover for last three years as per audit reports becomes Rs. 109,586,893 which is less than 02-times of quoted price. The bid declared Technically Non-Responsive due to: i) The schedule of technical data submitted with the bid is not conforming to tender specifications detailed below: a) Vacuum: 0.08 – 0.099 Mpa ii) The broucher / catalogue containing technical parameters is not signed & stamped.
Sarwar Electronics			99.000	The bid declared Commercially & Technically Responsive .
Unicom Corporation	---	---	19.940	The bid declared Non-Responsive because the bidder attached less 2% bid guarantee with the bid as per requirement.

Lowest Evaluated Bidder:

M/s Sarwar Electronics, Lahore

11. Any other additional/supporting information, the procuring agency may like to share.

Endst. No. 7836-37 /CE(Dev)PMU FESCO

Dated: 23-5-24

Forwarded to the Deputy Director, Public Procurement Regulatory Authority, 1st Floor, FBC Building, Near State Bank, Sector G-5/2, Islamabad for uploading at PPRA Website.


Chief Engineer (Development)
PMU, FESCO, Faisalabad

CC:-

1. Director General (IT) FESCO Faisalabad with the request to upload on FESCO website please.
2. Master File.